



Ref. Certif. No.

JPTUV-033701

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Independent Controlgear

Name and address of the applicant
Nom et adresse du demandeur

Led SMC Co., Ltd.
No. 28, 3rd Road
Ind. Park, Taipei 248
Taiwan

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

See additional page(s)

Rating and principal characteristics
Valeurs nominales et caractéristiques principales

Input: AC 100-240V; 50/60Hz; 1.8A or 2.1A or 1.7A or 1.4A or
1.2A; for details refer to the test report.
Output: refer to the test report; ta = 60 C; tc = 90 C

Trade mark (if any)
Marque de fabrique (si elle existe)

SPX-WX-YZ
(W=100, 120, 150 or 185; X=H or blank; Y=12, 15, 20, 24, 30,
36, 42, 48 or 54; Z=A, B or blank)

Model/type Ref.
Ref. de type

For model differences, refer to the test report.

Additional information (if necessary)
Information complémentaire (si nécessaire)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 61347-1:2007
IEC 61347-2-13:2006
National differences see test report

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue une partie de ce Certificat

11020492 001

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021 Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web: www.tuv.com

Date: 16.07.2010

Signature:

Dipl.-Ing. W. Hsu